

Declaration of Incorporation of Partly Completed Machinery in compliance with Machinery Directive 2006/42/EC

for electric actuators of the following type ranges:

SGC 04.1, SGC 05.1, SGC 07.1 , SGC 10.1, SGC 12.1
SGCR 04.1, SGCR 05.1, SGCR 07.1, SGCR 10.1, SGCR 12.1
SVC 05.1, SVC 07.1, SVC 07.5, SVCR 05.1, SVCR 07.1, SVCR 07.5

with integral actuator controls.

Manufacturer: AUMA Riester GmbH & Co KG, Aumastr. 1, 79379 Muellheim, Germany

The before mentioned actuators are intended for operation of industrial valves.

The following essential health and safety requirements in compliance with annex I of Directive 2006/42/EC are respected:

Articles 1.1.2, 1.1.3, 1.1.5, 1.2.1, 1.2.6, 1.3.1, 1.3.7, 1.5.1, 1.6.3, 1.7.1, 1.7.3, 1.7.4

AUMA shall be obligated to electronically submit the documents for the partly completed machinery to national authorities on request. The relevant technical documentation pertaining to the partly completed machinery described in annex VII, part B has been prepared.

Putting into service is not permitted until the final machinery into which the before mentioned actuators are to be incorporated has been declared in conformity with the provisions of the Directive 2006/42/EC.

Furthermore, the safety requirements of the **Low Voltage Directive 2014/35/EU** are fulfilled by applying the following harmonised standards, as far as applicable for the products:

EN IEC 61010-2-202:2021

Authorised person for documentation:

Michael Noll, Aumastr. 1, 79379 Muellheim, Germany

EU Declaration of Conformity

The manufacturer AUMA Riester GmbH & Co. KG declares herewith in sole responsibility, that the before mentioned devices meet the essential requirements of the following directives. The following harmonised standards were applied:

RoHS Directive 2011/65/EU

EN IEC 63000:2018

EMC Directive 2014/30/EU

EN 61800-3:2004/A1:2012

ATEX Directive 2014/34/EU

The above mentioned actuators are suitable for use in zone 22, category II 3D in a special version, according to their individual marking:

II 3D Ex tc IIIC T150 °C Dc

The following harmonised standards were applied:


EN IEC 60079-0:2018
EN 60079-31:2014

EN ISO 80079-36:2016
EN ISO 80079-37:2016

EN 1127-1:2019

Furthermore, the before mentioned standards of the **Low Voltage Directive 2014/35/EU** were applied.

Muellheim, 2023-07-01


Dr. J. Hoffmann, CEO